

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SDO PHE/667/18.06.2025Dated: 18.06.2025

It is certified that an inspection team headed by Shyam Doley (SDO)
(Name of Officers with designation) from Obedullaganj - Sub-Div

PHED inspected the Vaishnavi Public School Obedullaganj, Village Mendua, Bhojpur Road, Tehsil- Goharganj,
District- Raisen, MP on 13.6.2025 and on the basis of Water Test Report (Attached) bearing no.
letter no 664 dated 13.6.2025 of Sub-DN-Laboratory

(PHED Lab) certified that the Vaishnavi Public School Obedullaganj, Village Mendua, Bhojpur Road, Tehsil-
Goharganj, District- Raisen, MP has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per
norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 13.6.2026

Signature with seal

:-

ASSISTANT ENGINEER

Name

:-

Public Health Engineering

Designation

:-

Sub-Div.- Obedullaganj

ASSISTANT ENGINEER

Name & address of the office/Department: - PHE Obedullaganj

To,

Vaishnavi Public School Obedullaganj,

Village Mendua, Bhojpur Road, Tehsil- Goharganj, District- Raisen, MP

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies



सचिव

वैष्णवी पाटीदार शिक्षा एव
समाज कल्याण समिति, भोपाल



PRINCIPAL

VAISHNAVI PUBLIC SCHOOL

Test Report

Nature of sample:- Drinking Water Sample / Other		Not Sampled by S.D. Lab		Unique Identification No.
Sander's Name & Address Vaishnavi Public School	Sander's Letter No.		Sander's Letter date	12.06.2025
	S.D. Lab Ref. No.		S.D. Lab Receipt date	
	Date of analysis	12.06.2025	Date of analysis	12.06.2025
	Quantity of sample	OK		

Sample Details

No.	Block	Gram Panchayat	Village	Habitation	Location
1	Osedullaganj	Mendua	Mendua	-	Vaishnavi Public School, Japwate
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

Details of parameters, their test methods, units and specification as per BIS

No.	Characteristics	Test method BIS edition 3025		Unit	As per BIS-10500:2012 For Drinking Water Reaffirmed in June 2015	
					Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source
1	2	3	4	5	6	7
1	Iron Fe	BIS edition	3025	Mg/l	1	1
2	Nitrate as NO3	BIS edition	3025	Mg/l	45	45
3	Fluoride as F	BIS edition	3025	Mg/l	1	1.5
4	Chloride as Cl	BIS edition	3025	Mg/l	250	1000
5	Total Alkalinity as CaCO3	BIS edition	3025	Mg/l	200	600
6	Calcium	BIS edition	3025	Mg/l	75	200
7	Magnesium	BIS edition	3025	Mg/l	30	100
8	Sulphate as SO4	BIS edition	3025	Mg/l	200	400
9	Manganese as Mn	By Kit		Mg/l	0.1	0.3
10	pH	By Meter		PH Scale	6.5 to 8.5	6.5 to 8.5
11	Turbidity	By Meter		NTU	1	5
12	Total hardness as CaCO3	BIS edition	3025	Mg/l	200	600
13	Conductivity	By Meter		micromhos/cm	—	—
14	TDS	By Meter		Mg/l	500	2000
15	Faecal Coliform (TTC)	BIS edition	3025	per 100 ml	NIL	
16	Total Coliform	BIS edition	3025	per 100 ml	NIL for treated water and water in distribution	
17	Arsenic	By Kit		Mg/l	0.01	0.01

This report should not be produced partly or full without approval of signatory authority for legal purposes.

It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable. But still may be tolerated in the alternative source but up to limits indicated under the "permissible limit in the absence source" in column 6, above which the sources will have to be rejected.

The results refer only to tested samples and parameters tested.

Samples will be stored for a period of 15 days from the date of issue of report. (For test from S.No. 1 to 14)

This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

The tests marked with an not accredited by NABL.

सचिव
वैष्णवी पाटीदार शिक्षा एवं
समाज कल्याण समिति, भोपाल

PRINCIPAL
VAISHNAVI PUBLIC SCHOOL

Results of Samples

DISTRICT Raisen (Obaidulganj)

Sr no.	Date: 12/06/2025		S.D. Lab Ref No. 1								Date: 12.06.2025				Unique Identification No.							
Parameters/Units	Sample Number																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
Iron in Mg/l	0.12																					
Nitrate in Mg/l	2.0																					
Fluoride in Mg/l	0.10																					
Chloride in Mg/l	45																					
Alkalinity in Mg/l	320																					
Calcium in Mg/l	-																					
Magnesium in Mg/l	-																					
Sulphate in Mg/l	112																					
Manganese as mg/l	0.0																					
pH on pH scale	7.03																					
Turbidity in NTU	0.0																					
Hardness in Mg/l	250																					
Conductivity micro / cm	1533																					
TDS by meter	736																					
Faecal Coliform (TTC)	0																					
Coliform per 100 ml	0																					
Arsenic	0.03																					

This report should not be produced partly or full without approval or signatory authority for legal purposes.
It is recommended that acceptable limit is to be implemented. Values in excess in excess of those mentioned under "acceptable" render the water not suitable. But still may be tolerated in the alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" in column 6, above which the sources will have to be rejected.

The results refer only to tested samples and parameters tested.
Samples will be stored for a period of 15 days from the date of issue of report. (For test from s.No. 1 to 14)
This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
The tests marked with an not accredited by NABL.

marks:-
the sample is fit for drinking purpose for the parameters tested.

(Signature)
सचिव
तैबकी पाटीदार शिक्षा एवं
सामाजिक कल्याण समिति, भोपाल

PRINCIPAL
VAISHNAVI PUBLIC SCHOOL

CHIMIST
PHED...
CHEMIST
Sub Divisional Officer
PHE Sub Division, Obaidulganj, Raisen